Renewable source

Utility Grid

CHA HOUSING AUTHORITY

Solar Plus Storage Financial Analysis

Jan 2nd 2017 NU Microgrid Tean





Storage

Local Site

© COPYRIGHT INFORMATION

Microgrid Financial Analysis of Chicago Housing Authority.

© 2016 NU Microgrid Team.

All brand & product names and the brand logos, mentioned and used in this guide are trademarks or registered trademarks of their respective holders.

Executive Summary

Chicago Housing Authority's moderate tariff structure makes microgrid economical as well as qualitatively beneficial. Microgrid modeling tools were used to analyze the "Solar only" and "Solar+Storage" scenarios.

The "Solar+Storage" solution will help CHA offset their energy consumption by around 4million units (kWh) from the current scenario thus providing significant energy savings. Also CHA can further reduce their cost of energy considering ITC, SREC revenue and ancillary services benefits. Going forward this system can act as resilient power back up option and help CHA achieve their sustainability goals.

Analysis

Load profile considered for analysis: Year 2015

Note: For analysis, the peak load considered was 2,600kW which is a 30-min maximum demand interval (i.e. max of 30 min averages) instead of the instantaneous peak load 3,070 kW. This is how the utility companies calculate the average peak load.

Based on the current electricity consumption following is the annual cost for energy charges and demand charges for CHA's energy profile:

CHA ENERGY PROFILE (GRID ONLY)							
Consumption Cost (Avg) Annual Total Co							
Energy Load	11,558,629 kWh	Flat Charge: 5.9 cents/kWh	\$681,959				
Demand Load	2,600 kW (Peak Load)	\$6.86/kW/month	\$160,735				
Other Charges	NA	NA	\$181,326				
Total Charges	NA	NA	\$1,024,020				

Total Cost of Energy: 7.3 cents/kWh (Total Cost of Energy includes both energy charge and demand charge) **Other Charges:** Includes Fixed Costs (Metering Charge, Customer Service Charge, Non-Standard Facilities Charge), ComEd Franchise Cost & Taxes (State Tax, Municipality tax).



Cases

Following are the default results obtained after modeling the above load profile and tariff structure in HOMER*.

Case 1: SOLAR ONLY

- Based on the peak load of 2.6MW, HOMER suggests a 4.48 MW of PV.
- Hours of operation: 4,375hrs/yr (HOMER output)
- Power output: 8,595,028 kWh/yr (HOMER output)
- Sellback rate for excess solar energy: 2.7cents/kWh
- <u>Solar panel footprint</u>: Depending on the technology, typical 4.8 MW solar system would occupy anywhere between 241,024 sq. ft. to 321,365 sq. ft. (22,400 m² to 29,866 m²). **Roughly the size of four football fields.**

The revised cost of energy for "solar only" option is 3 cents/kWh (excluding the initial capital cost of the system). This yields energy savings of roughly \$495,592/ year and demand savings of roughly \$5,567/year. Including solar benefits, the total savings sum up to roughly \$501,159/year.

CHA ENERGY PROFILE (SOLAR ONLY)							
Consumption Cost (Avg) Annual Total Cos							
Energy Load	7,661,277 kWh	Flat Charge: 5.9 cents/kWh	\$186,368				
Demand Load	2,500 kW (Peak Load)	\$6.86/kW/month	\$155,168				
Other Charges	NA	NA	\$51,230				
Total Charges	NA	NA	\$392,766				

Other Charges: Includes Fixed Cost (Metering Charge, Customer Service Charge, Non-Standard Facilities Charge), ComEd Franchise Cost & Taxes (State Tax, Municipality tax). By benchmarking with current bill, other charges are estimated as ~14% to ~15% of the total energy & demand charge. i.e., Fixed Charges @ 1.6%, Franchise Cost @ 4.3% and taxes @ 9.2%

TOTAL SOLAR BENEFITS FOR 4.48 MW PV					
Energy + Demand Savings	\$501,159/year				
Total ITC*@ 30%	\$3,531,600				
Annual SREC* for 15 years	\$15,539,811				

Total Cost of Energy: 3 cents/kWh (Total Cost of Energy includes both energy charge and demand charge)

Disclaimer: The solar benefits considered may vary from state to state and client to client. The existence of such benefits is at the sole discretion of the government and the federal policies.



*HOMER (Hybrid Optimization of Multiple Energy Resources)

*Solar ITC

The Investment Tax Credit (ITC) is currently a 30 percent federal tax credit claimed against the tax liability of residential (Section 25D) and commercial and utility (Section 48) investors in solar energy property. This credit is used when a business purchases solar systems outright and have them installed on their facilities. In the case of the Section 48 credit, the business that installs, develops and/or finances the project claims the credit. For more: http://www.seia.org/policy/finance-tax/solar-investment-tax-credit

*SREC

Solar renewable energy credits (SRECs) are tradable credits that represent all the clean energy benefits of electricity generated from a solar energy system. Each time a solar energy system generates 1,000 kWh (1MWh) of electricity, an SREC is issued which can then be sold or traded separately from the power. The credit value depends on the state and local SREC market. In this case, SREC value starts at \$240 per solar credit in 1st year and decreases to \$78 per solar credit in year 15 considering the volatility of SREC market.

FINANCIAL SUMMARY

SOLAR ONLY (4.48 MW)						
With SREC Without SREC						
System Size	4.48 MW	4.48 MW				
Project Payback	2.5 Years	8.8				
IRR (20 Years)	26.6%	8%				
NPV	\$11.39 M	\$1.12 M				
CAPEX	\$11.74M	\$11.74M				

Key Assumptions: (all assumptions are based on industry standards)

- Solar Panel cost (includes transportation & installation costs) = \$2/watt

- Interest rate = 6%
- State Tax rate = 7.5%
- Federal Tax rate = 35%
- No ancillary services considered
- All costs used in the calculation are indicative.

CASE 2: SOLAR + STORAGE

Optimized Solar+Storage configuration from HOMER suggests 5000kW Solar and 4000kWh Flow battery storage.

Solar Output:

- Hours of operation: 4,375 hrs/yr (HOMER output)
- Power output: 8,595,028 kWh/yr (HOMER output)
- Sellback rate for excess solar energy: 2.7cents/kWh
- <u>Solar panel footprint</u>: Depending on the technology, typical 4.8 MW solar system would occupy anywhere between 241,024 sq. ft. to 321,365 sq. ft. (22,400 m² to 29,866 m²). **Roughly the size of four football fields.**

Storage Output:

- Annual Battery Throughput: 41,012 kWh/yr (HOMER output)
- <u>Storage footprint:</u> Depending on the technology, typical 1MW/4MWh flow battery would occupy 2,889 sq. ft. (268 m²), without service access. **Roughly the size of a tennis court.**

CHA ENERGY PROFILE (SOLAR + STORAGE)							
	Consumption Cost (Avg) Annual Total Cost						
Energy Load	7,673,261 kWh	Flat Charge: 5.9 cents/kW	\$18,771				
Demand Load	2,100 kW (Peak Load)	\$6.86/kW (avg. per month	\$14,657				
Other Charges	NA	NA	\$5,014				
Total Charges	NA	NA	\$38,442				

Other Charges: Includes Fixed Cost (Metering Charge, Customer Service Charge, Non-Standard Facilities Charge), ComEd Franchise Cost & Taxes (State Tax, Municipality tax). By benchmarking with current bill, other charges are estimated as ~14% to ~15% of the total energy & demand charge. i.e., Fixed Charges @ 1.6%, Franchise Cost @ 4.3% and taxes @ 9.2%

ANNUAL	ANCILLARY BENEFITS
Energy + Demand Savings	\$50,840/year
Frequency Regulation*	\$85,200/year
Demand response*	\$38,814/year
Arbitrage* (Net metering)	\$60,000/year
Total Savings (Energy + Ancillary)	\$692,415/year

Total Cost of Energy: 2.9 cents/kWh (Total Cost of Energy includes both energy charge and demand charge)

Disclaimer: The ancillary services benefits considered are based upon the existing PJM's program. The existence of such programs in future is at the sole discretion of PJM.



*Frequency regulation

Regulation is a service that corrects for short-term changes in electricity use that might affect the stability of the power system. It helps match supply and demand and adjusts output to maintain the desired electrical frequency for the grid to function normally.

*Demand Response Market

Demand response is a voluntary PJM program that allows end use customers to reduce their electricity usage during periods of higher power prices. In exchange, end-use (retail) customers are compensated through PJM members known as Curtailment Service Provider for decreasing their electricity use when requested by PJM.

*Arbitrage (Net Metering)

Arbitrage is the practice of charging the batteries during off peak period and use the stored energy during peak times in order to make the energy costs worthwhile. Using storage for "energy arbitrage" works better when there's a significant difference between the on-peak and off-peak electricity charge.

The revised cost of energy for solar+storage option is 2.9 cents/kWh (excluding the initial capital cost of the system). This yields an annual energy savings of roughly \$508,401/year. Including ancillary service benefits, the total savings sum up to roughly \$692,415/year.

FINANCIAL SUMMARY

SOLAR + STORAGE (4.8 MW + 4000kWh)							
	With Ancillary servicesWithout Ancillary Services						
SREC	With SREC	Without SREC	With SREC	Without SREC			
Project Payback	2.8 years	2.8 years 8.2 years		12 years			
IRR (20 year)	23.9%	8.4%	21.7%	5.6%			
NPV	\$11.89M	\$1.67M	\$9.98M	-\$0.24M			
CAPEX	\$14.27M	\$14.27M	\$14.27M	\$14.27M			

Key Assumptions: (all assumptions are based on industry standards)

- Solar Panel cost (includes transportation & installation costs) = \$2/watt

- Flow Battery cost (includes Schneider Controller costs & Installation costs) = \$730/kWh
- Interest rate = 6%
- State Tax rate = 7.5%
- Federal Tax rate = 35%
- Demand charge escalator = 3 % & ITC @ 30%
- All costs used in the calculation are indicative

QUALITATIVE BENEFITS

Following table highlights the qualitative benefits that CHA can have with a solar + storage configuration. A 4.48 MW + 4000 kWh solar plus storage system with significant energy savings will help CHA reduce their carbon footprint by a huge margin of 74%.

Gases	Only Grid	Solar + Storage	% Change
Carbon Dioxide	7,305,054	1,887,579	-74.16%
Sulphur Dioxide	31,671	8,183	-74.16%
Nitrogen Dioxide	15,489	4,002	-74.16%

Annual emissions are in metric tons

Conclusion

Based on the above analysis, we can see that the cost of energy for both "Solar only" and "Solar+Storage" configuration is significantly lower than the current cost of energy from grid. Considering SREC, ITC and ancillary services benefits "Solar+Storage" system has an attractive payback period of 2.8 years.

However, the SREC revenue stream over the 15 years can change based upon the policies prevailing at that time. Irrespective of the SREC revenue stream, the solar plus storage option with ancillary benefits based on a 1MW flow battery still has an attractive payback period of 8.2 years.

Note: While lithium ion batteries cost around \$700/kWh - \$800/kWh for a complete system including the O&M and replacement cost, Li-ion batteries are not considered in our analysis due to the following drawbacks,

- 1. Thermal runaway in Li-ion batteries can pose SAFETY issues thus making it unsuitable for commercial applications.
- 2. 50% capacity degradation over five to ten year period.
- 3. Higher lifetime cost per kWh.
- 4. Half the life time of flow batteries.

Tools Used



Economic and engineering optimization tool developed by National Renewable Energy Lab, US Department of Energy.



The Distributed Energy Resources Customer Adoption Model developed at Berkley Lab is used to verify HOMER's output.

Technical Appendix

SOLAR ONLY						
System Size	5MW 8MW 10MW					
SREC	With SREC	Without SREC	With SREC	Without SREC	With SREC	Without SREC
Project Payback	2.6 yrs	9.4 yrs	2.6 yrs	11 yrs	2.6 yrs	12 yrs
IRR (20 year)	26.10%	7.20%	25.40%	6.00%	25.00%	5.30%
NPV	\$12.20M	\$.74M	\$18.38M	\$.05M	\$22.15M	-\$.77M
САРЕХ	\$13.09M	\$13.09M	\$20.89M	\$20.89M	\$26.09M	\$26.09M

SOLAR + STORAGE (With Ancillary Benefits)						
System Size	5MW + 4MWh 8MW + 4MWh 10MW + 4MWh					+ 4MWh
SREC	With SREC	Without SREC	With SREC	Without SREC	With SREC	Without SREC
Project Payback	2.8 yrs	8.8 yrs	2.8 yrs	9.9 yrs	2.8 yrs	11 yrs
IRR (20 year)	23.70%	7.80%	23.90%	6.50%	23.80%	5.80%
NPV	\$12.71M	\$1.29M	\$18.88M	\$.59M	\$22.65M	-\$.22M
САРЕХ	\$15.62M	\$15.62M	\$23.42M	\$23.42M	\$28.62M	\$28.62M

SOLAR + STORAGE (Without Ancillary Benefits)						
System Size	5MW + 4MWh 8MW + 4MWh 10MW + 4MWh					
SREC	With SREC	Without SREC	With SREC	Without SREC	With SREC	Without SREC
Project Payback	3 yrs	12 yrs	2.9 yrs	13 yrs	2.9 yrs	14 yrs
IRR (20 year)	21.70%	5.10%	22.50%	4.70%	22.70%	4.30%
NPV	\$10.80M	-\$.61M	\$16.97M	-\$1.32M	\$20.74M	-\$2.13M
CAPEX	\$15.62M	\$15.62M	\$23.42M	\$23.42M	\$28.62M	\$28.62M

Technical Appendix

INDICATIVE COST DETAILS							
Cost Type	Solar Only (4.8 MW)	Total Cost	Solar+Storage (4.8MW + 4MWh)	Total Cost			
PV Module (25 yrs)	\$2/W	\$9,600,000	\$2/W	\$9,600,000			
PV O&M	\$0.01/W/yr	\$44,800/yr	\$0.01/W/yr	\$44,800/yr			
PV Inverter (10 yrs)	\$104/kW	\$465,920	\$104/kW	\$465,920			
PV Inverter O&M	\$1.2/kW/yr	\$5,600/yr	\$1.2/kW/yr	\$5,600/yr			
PV Inverter Replacement	\$42/kW	\$197,120	\$42/kW	\$197,120			
ES, Aux, Container (20 yrs)	-	-	\$382/kWh	\$1,527,680			
PCS/Inverter (20 yrs)	-	-	\$72/kWh	\$287,600			
BOS + Grid Tie	-	-	\$28/kWh	\$111,000			
ES/PCS Installation	-	-	\$121/kWh	\$484,500			
EMS	-	-	\$25/kWh	\$98,000			
Soft Costs	-	-	\$36/kWh	\$142,091			
Battery Replacement	-	-	\$68/kWh	\$270,093			
EMS Annual Maintenance	-	-	\$4/kWh	\$8,000/yr			
ES Inverter O&M	_	_	\$0.72/kWh	\$2,875/yr			
ES Inverter Replacement	-	-	\$34/kWh	\$137,000			

Note: PV - Photo Voltaic Solar Panels, ES - Energy Storage Units, O&M - Operations & Maintenance, Aux - Auxiliary Materials, PCS - Power Conversion System, BOS - Balance of System, EMS - Energy Management System.

All indicative costs were provided by: Schneider Electric for Inverters and Controllers, ViZn Energy for storage and components, Wanxiang for solar and components.

Appendix

1. Energy charges

Energy Charge is the measure of the charge obtained by multiplying the amount of electricity consumed over a specific period of time and the utility electricity charge over that period of time. It is measured in \$/kWh.

2. Demand Charges

Demand Charge is obtained by multiplying the instantaneous power (kW) consumed and the demand rate as per the contract with the utility partner. It is typically measured in the average of a 15minute period. It is measured in (\$/kW/ month)

3. Flow Battery

A flow battery is a fully rechargeable electrical energy storage device where fluids containing the active materials are pumped through a cell, promoting reduction/oxidation on both sides of an ion-exchange membrane, resulting in an electrical potential. In a battery without bulk flow of the electrolyte, the electroactive material is stored internally in the electrodes. However, for flow batteries, the energy component is dissolved in the electrolyte itself.

Below picture is for a 1MW/4MWh system configuration: (For representation purpose only)



Knowledge Base

1. How is a Microgrid different from smart grid?

The term 'Smart Grid' refers to the modernization of the electricity transmission and distribution system so that it automatically monitors, protects and optimizes the operation of its interconnected elements.

A Microgrid is a sustainable and reliable energy system comprising of a number of different energy sources capable of seamlessly operating on or off the provincial grid. Microgrid use smart grid technologies to enable the development of and operation of Microgrids.

2. What is the Microgrid Control System's role in the project?

Although the smart control system is not highly visible (compared to solar PV and wind turbine), it nonetheless is a critical component of PowerStream's Microgrid. The Microgrid Control System (MCS) is based on a supervisory control architecture providing the ability to monitor, track, and forecast load, generation and storage resources throughout the Microgrid. The MCS maximizes the use of renewables to provide power to the load in the most economical method possible in both grid-connected and islanded mode scenarios.

3. Is it possible to quantify the outage or downtime cost?

Yes. If you can estimate the dollar value of following applicable losses, it is possible to quantify the outage cost.

Cost of Downtime (per hour) = Lost Revenue + Lost Productivity + Cost to recover + Cost of intangibles (i.e. reputation cost)

- Do I get ancillary benefits when the microgrid operates in islanded mode? No. The ancillary services cannot be availed when the microgrid operates in the islanded mode.
- How much energy ViZn's 1MW/4MWh storage system can supply for 24 hours, 36 hours and 48 hours?

The 1MW/4MWh storage system can supply at a nominal power of 340kW for 8.8 hours. Hence the battery can supply approximately at 124.7 kW for 24 hours, at 83.1 kW for 36 hours, at 62.3 kW for 48 hours.